




*Southern Pipe, Inc.*

P. O. Box 606, 135 Random Drive, New London, NC 28127

Phone: 704-463-5202 Fax: 704-463-5203 www.southern-pipe.com

## Intermediate and Base Spacer Dimensions



Base spacers provide a 3" separation between the bottom row of ducts and the trench floor, except for the 4' x 1' size which is 1 3/4".

### Dimensional Data

Nominal Size	1" Separation			1 1/2" Separation			2" Separation			3" Separation		
	R	A	C	R	A	C	R	A	C	R	A	C
2"	Saddle spacers only			1.2	4.0	1.5	1.2	4.5	2.0	1.2	5.5	3.0
3"	Saddle spacers only			1.8	5.1	1.5	1.8	5.6	2.0	1.8	6.6	3.0
4"	2.3	5.6	1.0	2.3	6.1	1.5	2.3	6.6	2.0	2.3	7.6	3.0
5"	Saddle spacers only			2.9	7.3	1.5	2.9	7.9	2.0	2.9	8.9	3.0
6"	—	—	—	3.3	8.2	1.5	3.4	8.7	2.0	3.4	9.8	3.0
8"	—	—	—	4.3	10.2	1.5	4.3	10.7	2.0	—	—	—

All dimensions in inches